



## TEST REPORT nr. S17014101

### Safety (LVD)

#### Test item

Description.....: PID CONTROLLER FIVE SETPOINT 48x48  
 Trademark.....: PIXSYS  
 Model/Type .....: ATR244-12ABC

#### Test Specification

Standard.....: EN 60529:1991 + A1:2000 + A2:2013  
 Degree of protection (IP code): IP65

**Client's name** .....: PIXSYS S.r.l.

Address .....: Via della Croce Rossa, 42 – 35100 Padova (PD) – ITALY

**Manufacturer's name** : Same as client

Address .....: --

#### Report

Tested by .....: A. Borriero – *Technician*

*A. Borriero*

Approved by .....: R. Beghetto – *Laboratory Manager*

*R. Beghetto*

Date of issue .....: 07.02.17

Contents.....: 22 pages

This test report shall not be reproduced except in full without the written approval of CMC.  
 The test results presented in this report relate only to the item tested.



## 1. Summary

Reference standard:

EN 60529:1991 + A1:2000 + A2:2013

Clause	Test	Remark	Verdict
10.	Marking	IP65	P
11.	General requirements for the tests	--	P
12.	Protection against access to hazardous parts indicated by the first characteristic number	--	P
13.	Protection against solid foreign object indicated by the first characteristic number	--	P
14.	Tests for protection against water indicated by the second characteristic numeral	--	P

**Remarks:** Results are written following the exactly sequence of the performed measurement